

<b>COMPRESSED AIR CYLINDERS</b>		<b>TROY FIRE DEPT. TACTICAL PLAN 209.02</b>
<i>Issue</i>	<i>06/01</i>	<i>Page 1 of 1</i>

## **SCOPE**

This plan covers all compressed air cylinders owned by or filled by the Troy Fire Department.

## **CYLINDER TEST DATES**

All composite fiberglass cylinders must be hydrostatically tested every three years. All steel and aluminum cylinders must be hydrostatically tested every five years.

## **CYLINDER FILLING**

Prior to filling, each cylinder must be inspected for the last test date, and for any damage to the cylinder or valve. Any cylinder that is three years past the last test date, or that has damage to the valve, or fiberglass wrapping **MUST NOT BE FILLED.**

All cylinders will be filled within a protective enclosure.

The above rule pertains to any cylinder, whether it is owned by the TFD or not.